



1

## How to Participate Today

- Audio Modes
  - Listen using Mic & Speakers
  - Or, select "Use Telephone" and dial the conference (please remember long distance phone charges apply).
- Submit your questions using the Questions pane.
- A recording will be available for replay shortly after this webcast.

2

## Discussion Outline

### Background

- KUB Introduction

### Facility Overview, Drivers, Challenges

- Fourth Creek WWTP
- Kuwahee WWTP

### Technology Introduction

- Biologically Enhanced High Rate Clarification
- Pilot Summary
- System Design and Schedule

### Full-Scale Operation and Performance

### Questions

3

3

## Knoxville Utilities Board (KUB)

- KUB provides electric, natural gas, water, and wastewater services to more than 400,000 customers in and around Knoxville, TN.
- KUB owns and operates four wastewater treatment plants (WWTP)
- In February 2005, a Consent Decree with TDEC, USEPA, City of Knoxville, TN Clean Water Network and KUB became effective with the goal of eliminating sanitary sewer overflows (SSOs).
  - *KUB prepared Comprehensive Performance Evaluation (CPE) of our WWTPs and their ability to meet our NPDES permit requirements.*
  - *The results included the initiation of the Composite Correction Plan and Process Controls Plan*



4

## KUB Evaluation

- Four treatment facilities
  - Kuwahee wet weather treatment capacity for 70 MGD increased to 120 MGD
    - NPDES Violations from 2002-2005
      - 39 NPDES Permit violations
      - 126 Diversions and 16 bypasses
  - Fourth Creek WWTP full treatment capacity from 15 to 34 MGD
    - NPDES Violations from 2002-2005 (all associated with wet-weather conditions)
      - 45 total: 28 TSS, 8 settleable, 1 Fecal, 8 BOD
      - 92 Diversions and 12 bypasses
- **Three-tiered approach**
  - Fourth Creek and Kuwahee WWTP Improvements
  - Peak Storage/SSO Storage
  - Collection System Improvements – Reduce wet weather induced I/I
    - Average upgrade of 2% of system annually and pump station upgrades
    - Existing System Optimization (CMOM programs, CEPT, Biological treatment)

5

## KUB Evaluation

### **Criteria**

- Hydraulic and Biological Treatment limitations were found at both facilities
- Confirmation of existing system design capacities
  - Performance Evaluation + Hydraulic Modeling
- Wet Weather Diversions (Current and Future) – Frequency, duration and volume

### **Options**

- Collection system improvements won't mitigate diversions completely and is costly
- Detailed Evaluation Alternatives:

Diversion	Non-Diversion
CEPT	CEPT + BIOACTIFLO™ with Storage
CEPT + ACTIFLO® with Storage	CEPT + BIOACTIFLO™ without Storage
CEPT + ACTIFLO® without Storage	

- Both Deep Bed Filters and Full Biological Treatment ranked low and were determined infeasible (Site Constraints, Operational/Maintenance Challenges, BW disposal)


6

## KUB Evaluation


- Detailed Evaluation took into consideration:
  - *Performance Evaluation*
  - *Cost and Non-Cost factors*
  - *Diversion frequency*
  - *Implementation impacts*
- CEPT option alone, based on modeling, would not be able to consistently meet NPDES permit
- Recommendation
  - *Phased implementation of BIOACTIFLO™, to provide secondary treatment to peak, wet weather flows in excess of the capacity of the existing WWTP biological processes*
  - *Based on Hydraulic modeling of the 2-year, 24-hour storm event*

7

## KUB Evaluation



8



9

## Fourth Creek WWTP

- Location: Knoxville, TN
- Originally constructed in 1966
- Outfall into Tennessee River
- Permitted Flow: 10.8 MGD avg, 24 MGD peak
- Effluent TSS: 30 mg/L Daily Avg, 45 mg/L Daily Max
- Effluent BOD<sub>5</sub>: 30 mg/L Daily Avg, 45 mg/L Daily Max
- Constraints:
  - *Wet weather flow measurement peaked at 39 MGD*
  - *Hydraulic and Biological capacity limitations*
  - *Prior at 10.8 MGD*
    - Primary Clarifier 1.7 hours,
    - Secondary Clarifiers 2.5 hours

Google

10

## Fourth Creek WWTP




Figure 4-2  
Existing Fourth Creek WWTP Process Schematic

11

## Kuwahee WWTP

- Location: Knoxville, TN, Near Downtown/Univ. of Tennessee
- Originally constructed in the 1950's
- Outfall into Tennessee River
- Permitted Flow: 44 MGD avg, 70 MGD peak
- Effluent TSS: 30 mg/L Daily Avg, 45 mg/L Daily Max
- Effluent CBOD<sub>5</sub>: 25 mg/L Daily Avg, 40 mg/L Daily Max
- Constraints
  - Available footprint
  - Industrial Discharges
  - Hydraulic and Biological capacity limitations



12

# Kuwahee WWTP




Figure 4-1 Existing Kuwahee WWTP Process Schematic

13


# Technology Introduction



14

## ACTIFLO® for High Rate Clarification (HRC)

- ACTIFLO® for SSO/CSO Treatment
  - Physical / Chemical process using standard coagulation and flocculation practices
  - Uses sand as a ballast to increase the settling rate of the flocculated material
  - Rapid Start-up (15 min's) and high surface loading rates (50-70 gpm/sf)
  - Small Footprint with Minimal Equipment
  - Exceptional TSS and particulate BOD Removals
  - CON's – Limited soluble BOD reduction – Doesn't provide biological treatment of wet weather flows (if required)



15

## Biologically Enhanced High Rate Clarification (BEHRC)


- BIOACTIFLO™ for SSO/CSO Treatment
  - Pairs Contact Stabilization with ACTIFLO®
  - Contact Tank Facilitates sBOD uptake
  - Exceptional TSS and Total BOD Removals
  - Provides 100% biological treatment of all wet weather flows = MEETS SECONDARY STANDARDS




**BIOACTIFLO™**

16





17



18

## Performance in Wet Weather Applications

Configuration	TSS mg/l (% Rem)	BOD mg/l (% Rem)	Total Phosphorus mg/l	UV Transmittance % UVT	Geo Mean E. Coli after Disinfection MPN/100 ml
ACTIFLO®	< 15 (85 – 95%)	10 – 40 (40 – 65%)	0.1 – 0.3	65 - 80	< 15
BIOACTIFLO™	< 10 (90 – 98%)	5 – 10 (> 85%)*	0.1 – 0.2	70 - 85	< 15

\*Note: sBOD reduction in BIOACTIFLO™ contact tank allows for this increased total BOD reduction rate.


19

## Experience / Benefits


- Over 18 years of Wet Weather Treatment Experience
- 26 Wet Weather installations in operation
- 5 BIOACTIFLO™ facilities in operation
  - 3 more under construction / detailed design
- Intermittent or Continuous Use. Same Treatment train can handle variety of operating modes (Primary, Wet Weather, Tertiary)
- ACTIFLO® and BIOACTIFLO™ are cost effective solutions compared to other treatment options and provides the flexibility to handle variability in influent quality/flow
- BIOACTIFLO™ provides full secondary treatment to all wet weather flows



20




21



22

## Fourth Creek WWTP – System Design

- 2 x 9.5 MGD ACTIFLO® installed and commissioned in 2014
- Converted to BIOACTIFLO™ in 2018
  - Provisions were made in 2014 to help reduce conversion costs
  - Phased implementation helped identify unexpected issues and resolve them before starting KWWTP
- Anticipated Influent Conditions
  - BOD<sub>5</sub> (Avg / Max) – 141 mg/L / 230 mg/L
  - TSS (Avg / Max) – 130 mg/L / 260 mg/L
- Effluent Guarantees
  - > 85% removal of BOD<sub>5</sub>
  - > 85% removal of TSS



23

## Fourth Creek WWTP – Project Timeline

- Phase 1
  - CEPT Pilot testing early 2009
  - BIOACTIFLO™ Pilot testing in early 2010
  - Design and Construction of CEPT + ACTIFLO® + Storage – 2011 to 2013
  - ACTIFLO® commissioning and Performance Evaluation - 2014
- Phase 2
  - Design and Construction of BIOACTIFLO™ – 2016 to 2018
  - BIOACTIFLO™ commissioning - 2018



24


## Kuwahee WWTP – System Design

- 2 x 27.5 MGD BIOACTIFLO™ under construction
- Anticipated start-up – 3Q 2020
- Site Constraints
  - Existing Pre-Aeration Tank converted into Biological Contact Tank No. 1
  - Retrofitted existing Intermediate Storage Basins with ACTIFLO®, Chemical Building, Biological Contact Tank No. 2 and Pump Station
- Anticipated Influent Conditions
  - $BOD_5$  (Avg / Max) – 135 mg/L / 211 mg/L
  - TSS (Avg / Max) – 180 mg/L / 350 mg/L
- Effluent Guarantees
  - > 85% removal of  $BOD_5$
  - > 85% removal of TSS



25

## Kuwahee WWTP – System Design



26

## Kuwahee WWTP – System Design



27

## Kuwahee WWTP – Project Timeline


- Phase 1
  - CEPT Pilot testing early 2009
  - Design and Construction of Storage – 2008 to 2011
  - BIOACTIFLO™ Pilot testing in early 2010
  - Design and Construction of CEPT – 2010 to 2012
- Phase 2
  - Design and Construction of BIOACTIFLO™ – 2018 to 2020
  - BIOACTIFLO™ commissioning - 2020



28

## Full-Scale Operation

- Record Rainfall, I&I Issues – Late 2018, Early 2019
- Feb 2019 – Received over 13” rain (4X the 10-yr avg)
- Area wide impacts, widespread flooding lasting for days



Chilhowee Park

29

## Full-Scale Operation


- KUB treated over 4 billion gallons of water between Jan-Feb 2019
  - 34% increase compared to 2018
- BIOACTIFLO™ helped Fourth Creek handle historic flows and remain in compliance
  - 1 violation due to influent dilution with inflow

Fourth Creek WWTP	Average TSS	Average BOD <sub>5</sub>
Influent	63.5 mg/L (27 – 150 mg/L)	56.0 mg/L (15 – 140 mg/L)
Effluent	9.1 mg/L (2 – 19 mg/L)	4.6 mg/L (2 – 9 mg/L)
% Removal	81.3% (41% – 97%)	90.5% (80% - 94%)

Note – Based on 14 events between 12/21/2018 – 3/10/2019



30



31